



**CAL FIRE**  
**San Luis Obispo**  
**County Fire Department**

635 N. Santa Rosa • San Luis Obispo, CA 93405  
Phone: 805-543-4244 • Fax: 805-543-4248  
www.calfireslo.org



Robert Lewin, Fire Chief

January 29, 2014

County of San Luis Obispo  
Department of Planning & Building  
County Government Center  
San Luis Obispo, CA. 93408

Subject: DRC2013-00047 / Stine  
Proposed Minor Use Permit to modify distance from guesthouse to primary residence

Ms. Martin,

CAL FIRE/San Luis Obispo County Fire Department has recently reviewed the referral information and site plans provided for the request to modify the required separation distance for a proposed guesthouse to be located at 4095 Hampton Lane near Paso Robles, CA. The project site is located approximately **15** minutes from the nearest CAL FIRE/County Fire station. This site is located within an area classified as State Responsibility Area (SRA) having a **"High"** Fire Hazard Severity Zone designation.

This department supports the applicant's request to allow a modification to the required separation distance between the proposed guesthouse and the existing single family residence. The proposed project shall require an additional review and conditioning during the building permit process.

The following items will be required:

- A dedicated water storage tank and fire connection will be required for the proposed guesthouse. The existing tank and connection will not be sufficient to satisfy relative standards for the new project.
- Residential fire sprinklers will be required within the guesthouse.
- A Class A roof covering and non-combustible siding material will be required.

If I can provide additional assistance regarding this matter, please do not hesitate to contact me at (805)543-4244, extension 3425.

Sincerely,

Clinton I. Bullard  
Fire Inspector