




DEPARTMENT OF PLANNING AND BUILDING

THIS IS A NEW PROJECT REFERRAL



DATE: 2/6/2015

TO: P.W.

FROM: Cody Scheel (805-781-5157 or cscheel@co.slo.ca.us)
Coastal Team / Development Review

PROJECT DESCRIPTION: DRC2014-00080 PACIFIC GAS & ELECTRIC - Proposed minor use permit for addition of new modular trailers in Area 10 (12,000 sf) and removal of old fitness facility trailer (720 sf). Site location is 3890 Diablo Canyon Rd. APN: 076-011-018

Return this letter with your comments attached no later than: 14 days from receipt of this referral. CACs please respond within 60 days. Thank you.

PART 1 - IS THE ATTACHED INFORMATION ADEQUATE TO COMPLETE YOUR REVIEW?

- YES (Please go on to PART II.)
- NO (Call me ASAP to discuss what else you need. We have only 10 days in which we must obtain comments from outside agencies.)

PART II - ARE THERE SIGNIFICANT CONCERNS, PROBLEMS OR IMPACTS IN YOUR AREA OF REVIEW?

- YES (Please describe impacts, along with recommended mitigation measures to reduce the impacts to less-than-significant levels, and attach to this letter)
- NO (Please go on to PART III)

PART III - INDICATE YOUR RECOMMENDATION FOR FINAL ACTION.

Please attach any conditions of approval you recommend to be incorporated into the project's approval, or state reasons for recommending denial.

IF YOU HAVE "NO COMMENT," PLEASE SO INDICATE, OR CALL.

Flood Hazard review with construction Permits

2.15.15
Date

[Signature]
Name

5271
Phone

Area 10 Layout

Byrnes, Dennis@CALFIRE

Sent: Thursday, February 05, 2015 12:42 AM

To: Higgins, Joseph [JDH4@pge.com]

Cc: tewc@pge.com

Joe,

Regarding future development of Area 10 , CAL FIRE has no issues with placing modular building with in 5 feet of each other in this area. Due to that all modular buildings will be equipped with fire sprinklers and a limited building footprint, I agree with the placement and keeping a drive aisle around the modular buildings and between the existing structures. Please submit a copy of the site layout that you will be submitting to the San Luis Obispo County Planning/Building Department for your building permit, to CAL FIRE for our record and approval.

Any questions please let me know.

Thank You.

Dennis Byrnes

Fire Captain / Fire Prevention

CAL FIRE San Luis Obispo

635 N. Santa Rosa

San Luis Obispo, CA. 93405

805-543-4244 Office

805-543-4248 Fax