Miller Drilling Co.
329 N. Main St.
Templeton, CA 93465
(805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

Job# 19514

WELL OWNER: PASO OLIVIO
BILLING ADDRESS: 8530 VINEYARD DRIVE
PASO ROBLES, CA
93446

Pump Set: 262' Well #: 8"
Pump Size: 15 HP Well Depth: 280'
Testing Method: EXISTING PUMP
Perf Rec: 0-120 BLANK 120-280 SCREEN
APN:
LOCATION: 8530 VINEYARD DR

Standing Level Before Test: 112.60

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
9:25	START	CLOUDY		127
9:40	177.9	CLEARING		124
9:50	STOP	SET FLOW	105 GPM	
		SWL 120.1		
10:00	RESTART		6707068	105
10:05	155.8	CLEAR		104
10:10	161.6	CLEAR		104
10:20	165	CLEAR		104
10:30	165.4	CLEAR		104
		SAMPLES TAKEN		
1:30	174.8	CLEAR		104
1:45	174.9	CLEAR		104
2:00	175.2	CLEAR	6731644	104
	RECOVERY			
5 MIN	124.2			
10 MIN	123.9			
15 MIN	123.8			
25 MIN	122.5			

Notes: 6731644 102.40 GPM AVG
6703924

STANDING LEVEL AFTER TEST: 122.5 AFTER 25 MIN
FINAL TEST RESULTS: Produced: 104 GPM for 4 hours on: 12/10/2014
Test Run By: KURT