



*Gm*

SAN LUIS OBISPO COUNTY

DEPARTMENT OF PLANNING AND BUILDING

Promoting the wise use of land - Helping to build great communities

THIS IS A NEW PROJECT REFERRAL RECEIVED

APR 25 2016

COUNTY OF SAN LUIS OBISPO  
DEPARTMENT OF PUBLIC WORKS

DATE: 4/22/2016

PR TO:

*PW*

TO

FROM: Schani Siong (805-781-4374 or ssiong@co.slo.ca.us)  
Coastal Team / Development Review

PROJECT DESCRIPTION: DRC2015-00113 KEOUGH - Proposed minor use permit for the addition of a 598 sf detached shop/office. Project location is 1198 Pinewood Drive, Cambria. APN: 013-313-012

Return this letter with your comments attached no later than 14 days from receipt of this referral. CACs please respond within 60 days. Thank you.

PART I - IS THE ATTACHED INFORMATION ADEQUATE TO COMPLETE YOUR REVIEW?

- YES (Please go on to PART II.)
- NO (Call me ASAP to discuss what else you need. We have only 10 days in which we must obtain comments from outside agencies.)

PART II - ARE THERE SIGNIFICANT CONCERNS, PROBLEMS OR IMPACTS IN YOUR AREA OF REVIEW?

- YES (Please describe impacts, along with recommended mitigation measures to reduce the impacts to less-than-significant levels, and attach to this letter.)
- NO (Please go on to PART III.)

PART III - INDICATE YOUR RECOMMENDATION FOR FINAL ACTION.

Please attach any conditions of approval you recommend to be incorporated into the project's approval, or state reasons for recommending denial.

IF YOU HAVE "NO COMMENT," PLEASE SO INDICATE, OR CALL.

*SEE ATTACHED*

Date 4.27.16

Name Clan Marshall

Phone 781-1596



SAN LUIS OBISPO COUNTY  
ATTACHMENT 04  
**DEPARTMENT OF PUBLIC WORKS**

Wade Horton, Director

County Government Center, Room 206 • San Luis Obispo CA 93408 • (805) 781-5252

Fax (805) 781-1229

email address: [pwd@co.slo.ca.us](mailto:pwd@co.slo.ca.us)



Date: April 27, 2016

To: Schani Siong, Project Planner

From: Tim Tomlinson, Development Services

Subject: **Public Works Comments on DRC2015-00113 Keough MUP, Pinewood Dr., Cambria**

Thank you for the opportunity to provide information on the proposed subject project. It has been reviewed by several divisions of Public Works, and this represents our consolidated response.

---

**PUBLIC WORKS REQUESTS THAT AN INFORMATION HOLD BE PLACED ON THIS PROJECT UNTIL THE APPLICANT PROVIDES THE FOLLOWING DOCUMENTS FOR PUBLIC WORKS REVIEW AND COMMENT:**

1. Revised and resubmit site plan to remove proposed brick pavers from extending into the County right-of-way and show new driveway apron per B-1a rural road standards.
2. In accordance with the Land Use Ordinance, as the project is located in a Storm Water Management (MS4) Area, it is considered a regulated project and required to submit a Storm Water Control Plan Application and Coversheet:  
<http://www.slocounty.ca.gov/Assets/PL/Forms+and+Information+Library/Construction+Permit+Documents/Grading+and+Drainage+Documents/SWCP+Application+Pkg.pdf>

## Public Works Comments:

ATTACHMENT 04

- A. The proposed project is within the North Coast Road Fee Area. Payment of Road Improvement Fees is required prior to building permit issuance.
- B. The proposed project is within a drainage review area. Drainage plan is required to be prepared by a registered civil engineer and it will be reviewed at the time of Building Permit submittal by Public Works. The applicant should review Chapter 22.52.110 or 23.05.040 of the Land Use Ordinance prior to future submittal of development permits.
- C. The project meets the applicability criteria for Storm Water Management. Therefore, the project is required to submit a Storm Water Control Plan Application and Coversheet. The Storm Water Control Plan application and template can be found at:  
<http://www.slocounty.ca.gov/Assets/PL/Forms+and+Information+Library/Construction+Permit+Documents/Grading+and+Drainage+Documents/SWCP+Application+Pkg.pdf>

The Post Construction Requirement (PCR) Handbook can be found at:  
[http://www.slocounty.ca.gov/Assets/PL/Grading+and+Stormwater+Mgmt/new\\_stormwater/PCR+Handbook+1.1.pdf](http://www.slocounty.ca.gov/Assets/PL/Grading+and+Stormwater+Mgmt/new_stormwater/PCR+Handbook+1.1.pdf)

## Recommended Project Conditions of Approval:

### Access

1. **At the time of application for construction permits**, the applicant shall submit fees and plans to the Department of Public Works to secure an Encroachment Permit to reconstruct the project access driveway in accordance with County Public Improvement Standards.
2. **Prior to occupancy or final inspection**, all public improvements have been constructed or reconstructed in accordance with County Public Improvement Standards and to the satisfaction of the County Public Works Inspector.
3. **On-going condition of approval (valid for the life of the project)**, and in accordance with County Code Section 13.08, no activities associated with this permit shall be allowed to occur within the public right-of-way including, but not limited to, project signage; tree planting; fences; etc without a valid Encroachment Permit issued by the Department of Public Works.
4. **On-going condition of approval (valid for the life of the project)**, the property owner shall be responsible for operation and maintenance of public road frontage landscaping in a viable condition and on a continuing basis into perpetuity or until specifically accepted for maintenance by a public agency.

### Fees

5. **On-going condition of approval (valid for the life of the project)**, and in accordance with Title 13.01 of the County Code, the applicant shall be responsible for paying to the Department of Public Works the North Coast Road Impact Fee. The fee shall be imposed at the time of application for building permits and shall be assessed for each building permit to be issued. These fees are subject to change by resolution of the Board of Supervisors.

The applicant shall be responsible for paying the fee in effect at the time of application for building permits.

ATTACHMENT 04

### Drainage

6. **At the time of application for construction permits**, the applicant shall submit complete drainage plans for review and approval in accordance with Section 22.52.110 (Drainage) or 23.05.040 (Drainage) of the Land Use Ordinance.
7. **At the time of application for construction permits**, the applicant shall demonstrate that the project construction plans are in conformance with their Storm Water Control Plan.
8. **On-going condition of approval (valid for the life of the project)**, the project shall comply with the requirements of the National Pollutant Discharge Elimination System Phase I and / or Phase II storm water program and the County's Storm Water Pollution Control and Discharge Ordinance, Title 8, Section 8.68 et sec.

### Storm Water Control Plan

9. **At the time of application for construction permits**, the applicant shall demonstrate whether the project is subject to the LUO Section for Storm Water Management. Applicable projects shall submit a Storm Water Control Plan (SWCP) prepared by an appropriately licensed professional to the County for review and approval. The SWCP shall incorporate appropriate BMP's, shall demonstrate compliance with Storm Water Quality Standards and shall include a preliminary drainage plan, a preliminary erosion and sedimentation plan. The applicant shall submit complete drainage calculations for review and approval.
10. **At the time of application for construction permits**, if necessary, the applicant shall submit a draft "Private Storm Water Conveyance Management and Maintenance System" exhibit for review and approval by the County.
11. **Prior to issuance of construction permits**, if necessary, the applicant shall record with the County Clerk the "Private Storm Water Conveyance Management and Maintenance System" to document on-going and permanent storm drainage control, management, treatment, disposal and reporting.

ATTACHMENT 04

In regards to this preliminary review, a building permit is required. The drawings specify the work to be completed consists of a new detached shop/office of 598 sq ft. which is an accessory building to the existing residence. The project shall comply with current codes adopted by the County of San Luis Obispo (2013 California Building Standards Codes and Title 19 of the SLO County Codes).

While a thorough plan review will be conducted at time of building permit application, the following items are noted to assist design review;

- 1) Construction shall comply with the 2013 California Residential Code.
- 2) The design of the openings, projections, wall rating based on fire separation distance will need to be shown on the plans to comply with CRC Section 302, including Table 302.1(2) for buildings with sprinklers.
- 3) Provide plans which clearly show the structural design to verify compliance with the prescriptive requirements of the 2013 California Residential Code or any structural element not complying with the prescriptive requirements will need to be prepared by a California Licensed Design Professional (Architect or Engineer) justifying the structural design
- 4) Provide electrical plans with notes to show the location of the main electrical panel, sub-panels, receptacles, lights, switches, and smoke detectors and Co alarms to verify compliance with the 2013 California Electrical Code.
- 5) Provide notes and information on the plans for the plumbing fixtures requirements, the design of the waste lines, vents, and water lines will all need to comply with the 2013 California Plumbing Code.
- 6) Energy calculation will need to be submitted to verify compliance with the 2013 California Energy Code.
- 7) The plans will need show compliance with the 2013 California Green Building Code and the County of San Luis Obispo's Green Building Ordinance.
- 8) Fire sprinklers will be required for this project and will need to be submitted under a separate permit application. Provide plans showing the design and layout for the sprinkler system.